

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : Textile Mania Pty Ltd
560 Swan Street
Richmond VIC 3121

Test Number : 17-000851
Issue Date : 16/03/2017
Print Date : 28/03/2017
Order Number : 22603

Sample Description Clients Ref : "11608 3D Block"
Woven Upholstery fabric
Colour : Green/Navy
End Use : Upholstery
Nominal Composition : 85% Wool, 15% Nylon
Nominal Mass per Unit Area/Density : 380g/m2
Nominal Thickness : 0.82mm

**AS/NZS 1530.3-1999
(Modified)**

**Method for Fire Tests on Building Materials, Components and Structures. Part 3
Simultaneous Determination of Ignitability, Flame Propagation, Heat Release and
Smoke Release - Guidance Test**

	1	2
Ignitability Index (Range 0-20)	0	0
Spread of Flame Index (Range 0-10)	0	0
Heat Evolved Index (Range 0-10)	0	0
Smoke Developed Index (Range 0-10)	3	4

86564

17772

Page 1 of 2

© Australian Wool testing Authority Ltd
Copyright - All Rights Reserved

Accredited for compliance with ISO/IEC 17025

- Chemical Testing	: Accreditation No.	983
- Mechanical Testing	: Accreditation No.	985
- Performance & Approvals Testing	: Accreditation No.	1356

Samples, and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. The above test results are designed to provide THE CLIENT WITH GUIDANCE INFORMATION ONLY. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved in advance by the Managing Director of AWTA Ltd.



AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : Textile Mania Pty Ltd
560 Swan Street
Richmond VIC 3121

Test Number : 17-000851
Issue Date : 16/03/2017
Print Date : 28/03/2017
Order Number : 22603

The reaction of thin unsupported flexible materials to flame impingement can be assessed in accordance with AS 1530.2. Where materials of thickness less than 2mm that are sufficiently flexible to be bent by hand around a mandrel of 2mm diameter or less are subjected to the test described herein, they should also be subjected to the test in AS 1530.2.

Ignition is initiated by a pilot flame that is held near, but does not touch the specimen. A material that does not ignite during the standard test may ignite if contacted with a pilot flame during the test.

Each test specimen had an unattached backing of 4.5mm thick fibre reinforced cement board.

Each test specimen was restrained on the exposed face by a layer of galvanised welded square mesh made from wire of nominal diameter 0.8mm and nominal spacing 12mm in both directions and securely fixed to a backing board at four points each 100mm from the centre of the sample and the assembly clamped in four places.

To allow free movement of sample during testing all corners were folded away from the clamps.

The results only apply to the specimen mounted as described in this report.

A reduced number of specimens were tested to provide guidance only as to the likely performance of the product tested.

86564

17772

Page 2 of 2

© Australian Wool testing Authority Ltd
Copyright - All Rights Reserved

Accredited for compliance with ISO/IEC 17025

- Chemical Testing	: Accreditation No.	983
- Mechanical Testing	: Accreditation No.	985
- Performance & Approvals Testing	: Accreditation No.	1356

Samples, and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. The above test results are designed to provide THE CLIENT WITH GUIDANCE INFORMATION ONLY. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved in advance by the Managing Director of AWTA Ltd.



APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)
MANAGING DIRECTOR